



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of the BACnet Manufacturers Association (BMA). BTL is a registered trademark of the BMA.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BMA website.

Listing Information

Vendor		Listing Status
Automated Logic Corporation 1150 Roberts Boulevard Kennesaw, GA 30144-3618		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2004	135-2001	January 2004

Product Name	Model Number	Software Version
SE6104 Single Equipment Control Module	SE6104	1.72:054

Product Name	Link to PICS on BMA Website
SE6104 Single Equipment Control Module	http://bacnetassociation.org/BMAProductCatalog/AutomatedLogic/AutomatedLogicAll.htm

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-AAC)	SE6104

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B

Alarm and Event Management	NotificationInternal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	AlarmSummary-B	AE-ASUM-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Device and Network Management	ReinitializeDevice-B	DM-RD-B
	DynamicDeviceBinding-A	DM-DDB-A
	DynamicDeviceBinding-B	DM-DDB-B
	DynamicObjectBinding-A	DM-DOB-A
	DynamicObjectBinding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	File	Schedule
Calendar	Multi-State Value	Notification Class
Program		

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800 baud

Character Set Support

<input checked="" type="checkbox"/> ANSI X3.4	<input type="checkbox"/> IBM™/Microsoft™ DBCS	<input type="checkbox"/> ISO 8859-1
<input type="checkbox"/> ISO 10646 (UCS-2)	<input type="checkbox"/> ISO 10646 (ICS-4)	<input type="checkbox"/> JIS C 6226